



LGU - LINGAYEN

**BAC**

BIDS AND AWARDS COMMITTEE

## BID SUPPLEMENT

In reference to Invitation to Bid for the *Procurement of Two (2) units Generator Sets with Complete Accessories to be delivered at Lingayen Municipal Hall, Lingayen, Pangasinan* with an Approved Budget for the Contract of *One Million Nine Hundred Eighty Two Thousand Four Hundred Pesos Only (P1,982,400.00) only* which was published, where certain components and technical specifications has been overlooked when being encoded. Thus, said procurement shall have the following revisions:

<i>FROM</i>	<i>TO</i>
<b>SECTION III. BID DATA SHEET (BDS) Clause 19.3 / SECTION VI. SCHEDULE OF REQUIREMENTS / SECTION VII. TECHNICAL SPECIFICATION</b>	<b>SECTION III. BID DATA SHEET (BDS) Clause 19.3 / SECTION VI. SCHEDULE OF REQUIREMENTS / SECTION VII. TECHNICAL SPECIFICATION</b>
<p><b>One (1) unit GENERATOR SET (100KVA with ATS)</b></p> <p><i>Specifications:</i>            Output Voltage- 220-240 Volts            Phase System- Single (1) Phase            Frequency- 60 Hertz            Unit Type- Enclosed / Silent Type            Warranty- 1 year or 1000 running hours whichever comes first            Diesel Engines            Brushless AC Alternator            Digital Controller            Set Mounted Radiator            Industrial Muffler and flexible bellows (set mounted)            Set Mounted Circuit Breaker            Skid Mounted Fuel Tank            Battery with Automatic Battery Charger            Manual and door keys            Testing and Commissioning            Delivery at Lingayen Municipal Hall</p> <p><b>One (1) unit GENERATOR SET (50KVA with ATS)</b></p> <p><i>Specifications:</i>            Output Voltage- 220-240 Volts            Phase System- Single (1) Phase            Frequency- 60 Hertz            Unit Type- Enclosed / Silent Type            Warranty- 1 year or 1000 running hours whichever comes first            Diesel Engines            Brushless AC Alternator            Digital Controller            Set Mounted Radiator            Industrial Muffler and flexible bellows (set mounted)            Set Mounted Circuit Breaker</p>	<p><b>One (1) GENERATOR SET</b></p> <p><i>Minimum Requirements :</i>            150 KVA with ATS            Output Voltage- 220-240 Volts            Phase System- Single (1) Phase            Frequency- 60 Hertz            Unit Type- Enclosed / Silent Type            Warranty- 1 year or 1000 running hours whichever comes first            Diesel Engines            Brushless AC Alternator            Digital Controller            Set Mounted Radiator            Industrial Muffler and flexible bellows (set mounted)            Set Mounted Circuit Breaker            Skid Mounted Fuel Tank            Battery with Automatic Battery Charger            Manual and door keys            Testing and Commissioning            Delivery at Lingayen Municipal Hall            Certificate of Importation</p> <p><b>One (1) GENERATOR SET</b></p> <p><i>Minimum Requirements :</i>            50 KVA with ATS            Output Voltage- 220-240 Volts            Phase System- Single (1) Phase            Frequency- 60 Hertz            Unit Type- Enclosed / Silent Type            Warranty- 1 year or 1000 running hours whichever comes first            Diesel Engines            Brushless AC Alternator            Digital Controller            Set Mounted Radiator            Industrial Muffler and flexible bellows (set mounted)</p>

HON. LEOPOLDO N. BATAOG  
 Municipal Mayor

*Chairperson*

JOAN JUDE R. LOPEZ LLB, ADM.  
 Municipal Civil Registrar

*Vice-Chairperson*

ROBERTO DS. SYLIM  
 Municipal Administrator

*BAC Members:*

JEANNE IRAYDA N. GOMEZ  
 Municipal Budget Officer

ATTY. DOMINIQUE C. EVANGELISTA  
 Municipal Legal Officer

RAJK A. LINSON  
 Chief Administrative Officer

ENGR. JEROME V. CANULLAS  
 Municipal Assessor

ARCH. NELCO PAUL P. COQUA, EnP  
 MPDC

*Technical Working Group:*

LARRY B. FLORES  
 Municipal General Services Officer

ENGR. JOHN SYLVESTER A. TAPIA  
 Municipal Engineer

NELSON S. GUMAPOD  
 Municipal Accountant

*BAC Secretariat:*

ARNULFO S. BERNARDO  
 Market Supervisor IV - HEAD

SHARON S. SISON  
 Administrative Officer IV

AREANNE GRACE M. DE GUZMAN  
 Administrative Officer III

CEZAR IAN B. FERNANDEZ  
 Security Officer II

MYRA B. GARCIA  
 Revenue Collection Clerk II




Republic of the Philippines  
**MUNICIPALITY OF LINGAYEN**  
Province of Pangasinan

Skid Mounted Fuel Tank  
Battery with Automatic Battery Charger  
Manual and door keys  
Testing and Commissioning  
Delivery at Lingayen Municipal Hall

Set Mounted Circuit Breaker  
Skid Mounted Fuel Tank  
Battery with Automatic Battery Charger  
Manual and door keys  
Testing and Commissioning  
Delivery at Lingayen Municipal Hall  
Certificate of Importation

Issued this 17<sup>th</sup> day of November 2021 at Lingayen, Pangasinan.

Prepared by:

  
**ARNULFO S. BERNARDO** *h*  
Head, BAC Secretariat

Certified by:

  
**JOAN JUDE R. LOPEZ, LLB, MDM**  
BAC Chairperson