



BAC

BID SUPPLEMENT

In reference to Invitation to Bid for the *Procurement of Two (2) Generator Sets with Complete Accessories to be delivered at Lingayen Municipal Hall, Lingayen, Pangasinan* with an Approved Budget for the Contract of *One Million Nine Hundred Eighty Two Thousand Four Hundred Thousand Pesos (P1,982,400.00) Only* which was published, where certain components and technical specifications has been overlooked when being encoded, Thus, said procurement shall have the following revisions:

FROM	TO
<p>Section III BID DATA SHEET (BDS) Clause 19.3 Section VII Technical Specifications Section VI Schedule of Requirements</p>	<p>Section III BID DATA SHEET (BDS) Clause 19.3 Section VII Technical Specifications Section VI Schedule of Requirements</p>
<p>1 set Generator, 150kVa <i>Specifications/Minimum Requirements:</i> With transfer switch (400 amp) Output Voltage: 220-240volts Phase System: Single Phase Frequency: 60 hertz Unit Type: enclosed/silent type Warranty: minimum of one (1) year or 1000 running hours whichever comes first Diesel Engine, Euro 4 Brushless AC alternator Digital controller Set Mounted Radiator Industrial Muffler and flexible bellows (set mounted) Set mounted circuit breaker Skid Mounted Fuel Tank Battery with automatic battery charger Manual and door keys Testing and commissioning Water Cooled Electric Start Engine description Delivery at Lingayen Municipal Hall</p>	<p>1 set Generator, 150kVa <i>Specifications/Minimum Requirements:</i> With transfer switch (400 amp) Output Voltage: 220-240volts Phase System: Single Phase Frequency: 60 hertz Unit Type: enclosed/silent type Warranty: minimum of one (1) year or 1000 running hours whichever comes first Diesel Engine, <i>Environmental Compliance Certificate from Department of Environment and Natural Resources</i> Brushless AC alternator Digital controller Set Mounted Radiator Industrial Muffler and flexible bellows (set mounted) Set mounted circuit breaker Skid Mounted Fuel Tank Battery with automatic battery charger Manual and door keys Testing and commissioning Water Cooled Electric Start Engine description Delivery at Lingayen Municipal Hall Extended Muffler mounted outside the Lingayen Civic Center Maximum Length – 3,000mm , Maximum Width – 1,200mm , Maximum Height – 1,700mm , Maximum Weight – 1,800kg Fuel Capacity – 202 liters Fuel Consumption – 34 liters/hour (full throttle) With External Battery Charger Decibel- Maximum of 69</p>

Head of Procuring Entity

MDN. LEOPOLDO N. BATAOIL
 Municipal Mayor

Chairperson

JOAN JUDE R. LOPEZ, LLB, MDM.
 Municipal Civil Registrar

Vice-Chairperson

ROBERTO DG. SYLIM
 Municipal Administrator

BAC Members:

JEANNE IRAYDA N. GOMEZ
 Municipal Budget Officer

ATTY. DOMINIQUE C. EVANGELISTA
 Municipal Legal Officer

RAUL A. UNGSON
 Chief Administrative Officer

ENGR. JEROME V. CANULLAS
 Municipal Assessor

ARCH. NELCO PAUL P. COQUIA, EnP
 MPDC

Technical Working Group:

LARRY B. FLORES
 Municipal General Services Officer

ENGR. JOHN SIVESTER A. TAPIA
 Municipal Engineer

NELSON S. GUMAPOS
 Municipal Accountant

BAC Secretariat:

ARNULFO S. BERNARDO
 Market Supervisor IV – HEAD

SHARON S. SISON
 Administrative Officer IV

AREANNE GRACE M. DE GUZMAN
 Administrative Officer III

CEZAR IAN B. FERNANDEZ
 Security Officer II

MYRA B. GARCIA
 Revenue Collection Clerk II



Republic of the Philippines
MUNICIPALITY OF LINGAYEN
Province of Pangasinan

<p>1 set Generator, 50kVa <i>Specifications/Minimum Requirements:</i> With transfer switch (200 amp) Output Voltage: 220-240volts Phase System: Single Phase Frequency: 60 hertz Unit Type: enclosed/silent type Warranty: minimum of one (1) year or 1000 running hours whichever comes first Diesel Engine, Euro 4 Brushless AC alternator Digital controller Set Mounted Radiator Industrial Muffler and flexible bellows (set mounted) Set mounted circuit breaker Skid Mounted Fuel Tank Battery with automatic battery charger Manual and door keys Testing and commissioning Water Cooled Electric Start Engine description Delivery at Lingayen Municipal Hall</p> <p>-----nothing follows-----</p>	<p>1 set Generator, 50kVa <i>Specifications/Minimum Requirements:</i> With transfer switch (200 amp) Output Voltage: 220-240volts Phase System: Single Phase Frequency: 60 hertz Unit Type: enclosed/silent type Warranty: minimum of one (1) year or 1000 running hours whichever comes first Diesel Engine, <i>Environmental Compliance Certificate from Department of Environment and Natural Resources</i> Brushless AC alternator Digital controller Set Mounted Radiator Industrial Muffler and flexible bellows (set mounted) Set mounted circuit breaker Skid Mounted Fuel Tank Battery with automatic battery charger Manual and door keys Testing and commissioning Water Cooled Electric Start Engine description Delivery at Lingayen Municipal Hall <i>Extended Muffler mounted outside the Lingayen Civic Center</i> <i>Maximum Length – 2,400mm ,</i> <i>Maximum Width – 1,100mm , Maximum</i> <i>Height – 1,500mm , Maximum Weight – 1,200kg</i> <i>Fuel Capacity – 140 liters</i> <i>Fuel Consumption – 15 liters/hour (full throttle)</i> <i>With External Battery Charger</i> <i>Decibel- Maximum of 69</i></p> <p>-----nothing follows-----</p>
--	--

Issued this 10th day of February 2022 at Lingayen, Pangasinan.

Prepared by:

ARNULFO S. BERNARDO
Head, BAC Secretariat

Certified by:

JOAN JUDE R. LOPEZ, LLB, MDM
BAC Chairperson