

Name of Project: Procurement of Two(2) Generator Sets with Complete Accessories to be delivered at Lingayen Municipal Hall, Lingayen, Pangasinan
ABC: P1,982,400.00

Date: _____

Quotation No: _____

The Manager

Please quote your lowest price on the item/s listed below, stating the shortest time of delivery and submit your quotation duly signed not later than April 18, 2022. Late submission shall not be accepted.

LARRY B. FLORES

Municipal General Services officer

IMPORTANT INSTRUCTIONS:

1. **DELIVERY PERIOD IS NINETY(90) CALENDAR DAYS**
2. **WARRANTY SHALL BE FOR A PERIOD OF SIX (6) MONTHS FOR SUPPLIES & MATERIALS, ONE (1) YEAR FOR EQUIPMENT, FROM DATE OF ACCEPTANCE BY THE PROCURING ENTITY**
3. **PAYMENTS SHALL BE MADE THRU CHEQUE WITHIN FIFTEEN (15) DAYS AFTER THE DELIVERY, AND SHALL BE CLAIMED PERSONALLY AT THE OFFICE OF THE MUNICIPAL TREASURER**
4. **THE PRICE OFFERED SHALL NOT BE SUBJECT TO ANY INCREASE FOR WHATEVER REASON INCLUDING IN CASES OF DEVALUATION/INFLATION DURING THE ENTIRE DURATION OF THE CONTRACT**
5. **PRICE SHALL BE INCLUSIVE OF VAT**
6. **THE QUOTATION SHALL NOT BE CONSIDERED UNLESS IT IS PROPERLY SIGNED BY THE AUTHORIZED REPRESENTATIVE.**
7. **BIDDER'S MUST SUBMIT THE FF. REQUIREMENTS**
 - A) **VALID AND CURRENT MAYOR'S PERMIT**
 - B) **VALID AND CURRENT PHILGEPS CERTIFICATE**
 - C) **LATEST INCOME/BUSINESS TAX RETURN**
8. **COMPLETELY FILL OUT THE PRICE QUOTATION FORM, TECHNICAL SPECIFICATION/BRAND (IF APPLICABLE), UNIT/TOTAL PRICE AND SUPPLIER/BIDDER'S INFORMATION. DO NOT FORGET TO SIGN THE PRICE QUOTATION FORM**
9. **A BIDDER WHO SUBMITS A QUOTATION IS REQUIRED TO DOWNLOAD THIS RFQ FROM THE PHILGEPS WEBSITE BEFORE THE CLOSING DATE FOR INCLUSION IN THE PHILGEPS DOCUMENT REQUEST LIST (DRL).**
10. **DOWNLOADED QUOTATION MUST BE SUBMITTED THRU FAX, EMAIL OR DIRECTLY TO THE BAC SECRETARIAT ON OR BEFORE THE CLOSING DATE OF BID NOTICE ABSTRACT**

| Item No. | ITEM & DESCRIPTION | QTY. | UNIT PRICE | TOTAL PRICE |
|----------|---|-------|------------|-------------|
| 1 | Generator, 150kVa <i>Specifications/ Minimum Requirements:</i> With transfer switch (400 amp) Output Voltage: 220-240 volts Phase System: Three (3) Phase Frequency: 60 hertz Unit Type: enclosed/ silent type Warranty: minimum of one (1) year or 1000 running hours whichever comes first Diesel Engine, Environmental Compliance Certificate from Department of Environment and Natural Resources Brushless AC alternator Digital controller Set Mounted Radiator Industrial Muffler and flexible bellows (set mounted) Set mounted circuit breaker Skid Mounted Fuel Tank Battery with automatic battery charger Manual and door keys Testing and commissioning Water Cooled Electric Start Engine description Delivery at Lingayen Municipal Hall | 1 set | | |

| | | | | |
|--|---|-------|-----------------|--|
| | <p>Extended Muffler mounted outside the Lingayen Municipal Hall Maximum Length-3,000mm, Maximum Width- 1,200mm, Maximum Height- 1,700mm, Maximum Weight- 1,800kg Fuel Capacity- 202 liters Fuel Consumption- 34 liters/ hour (full throttle) With External Battery Charger Decibel- Maximum of 69</p> | | | |
| | <p>Generator, 50kVa <i>Specifications/ Minimum Requirements:</i> With transfer switch (200 amp) Output Voltage: 220-240volts Phase System: Three (3) Phase Frequenzy: 60 hertz Unit Type: enclosed/silent type Warranty: minimum of one (1) year or 1000 running hours whichever comes first Diesel Engine, Environmental Compliance Certificate from Department of Environment and Natural Resources Brushless AC alternator Digital controller Set Mounted Radiator Industrial Mufler and flexible bellows (set mounted) Set mounted circuit breaker Skid Mounted Fuel Tank Battery with automatic battery charger Manual and door keys Testing and commissioning Water Cooled Electric Start Engine description Delivery at Lingayen Municipal Hall Extended Muffler mounted outside the Lingayen Municipal Hall Maximum Length -2,400mm, Maximum Width- 1,100mm, Maximum Height- 1,500mm, Maximum Weight- 1,200kg Fuel Capacity-140 liters Fuel Consumption – 15 liters/hour (full throttle) With External Battery Charger Decibel- Maximum of 69 -----nothing follows-----</p> | 1 set | | |
| | | | TOTAL--- | |

Printed Name/Signature

Tel. No./Cellphone No. E-mail address

PhilGEPS Registration No.

Date